LINCOLN/LANCASTER COUNTY PLANNING STAFF REPORT

for November 24, 2004 PLANNING COMMISSION MEETING

P.A.S.: Waiver #04016

PROPOSAL: Waive the sidewalk in the pedestrian easement associated with

Corrected Plat of Edenton South 10th Addition Final Plat #97034

LOCATION: S. 70th Street & Old Cheney Rd.

CONCLUSION: Corrected plat of Edenton South 10th Addition final plat was approved

on September 10, 1997. The Resolution required that the sidewalk within the pedestrian easement be installed at the same time that Culwells Court is paved. The damming effect can be alleviated with culverts in the swale area under the sidewalk. This waiver request does

not meet the conditions of Section 26.31.010.

RECOMMENDATION: Denial

GENERAL INFORMATION:

LEGAL DESCRIPTION: Outlot "A", corrected plat of Edenton South 10th Addition, located

in the NW 1/4 of Section 15, Township 9, Range 7, Lancaster

County, NE

EXISTING ZONING: R-3, Residential

EXISTING LAND USE: Attached two-family dwellings and open space.

SURROUNDING LAND USE AND ZONING:

North: R-1, Residential Single family dwellings

South: R-3, Residential Attached two-family dwellings

East: R-1, Residential Single family dwellings

R-3, Residential Attached two-family dwellings

West: R-3, Residential Church

HISTORY:

September 10, 1997 Corrected Plat of Edenton South 10th Addition Final Plat was

approved by the Planning Commission.

<u>Waiver #04016</u> <u>Page 2</u>

October 23, 1996 Edenton South 10th Addition Final Plat was approved by the

Planning Commission.

July 22, 1996 Edenton South 1st Addition Preliminary Plat #96005 and Special

Permit #1607 were approved by the City Council.

COMPREHENSIVE PLAN SPECIFICATIONS:

"Interconnected networks of streets, trails, and sidewalks should be designed to encourage walking and bicycling, reduce the number and length of automobile trips, conserve energy and for the convenience of the residents." (F-18)

"Transit, pedestrian, and bicycle networks should maximize access and mobility to provide alternatives and reduce dependence upon the automobile." (F-19)

"Streets and public spaces should be safe, comfortable, and interesting to the pedestrian." (F-19)

"Sidewalks should be provided on both sides of all streets, or in alternative locations as allowed through design standards or the Community Unit Plan process." (F-66)

"Interconnected networks of streets, trails and sidewalks should be designed to encourage walking and bicycling and provide multiple connections within and between neighborhoods." (F-66)

The sidewalk system should be complete and without gaps." (F-89)

TRAFFIC ANALYSIS: S. 70th St. and Old Cheney Rd. are classified as arterials.

Culwells Ct. is a private roadway.

ANALYSIS:

- 1. This is a request to eliminate the sidewalk within a pedestrian easement.
- 2. Section 26.27.020 of the Land Subdivision Ordinance states that sidewalks shall be constructed on both sides of all streets within the subdivision and on the side of the streets abutting the subdivision.
- 3. A condition for approval of the final plat was to install the sidewalk in the pedestrian easment as shown on the final plat or post a surety in the amount of \$1,000.00. A surety in the amount of \$1,000.00 was posted.
- 4. The subdivision agreement for Edenton South 10th Addition states that the subdivider agrees to complete the private improvements shown on the preliminary plat and use permit, which includes the sidewalk in the pedestrian easement.

<u>Waiver #04016</u> Page 3

5. The sidewalk was required to be installed at the same time Culwells Court was paved. The omission of installing the sidewalk at the required time does not justify a hardship.

- 6. Section 26.23.125 of the Land Subdivision Ordinance requires a pedestrian way when a block exceeds 1,000 feet in length and where needed for pedestrian traffic. This block length is well in excess of 1,000 feet.
- 7. Without this pedestrian way, pedestrians/bicyclists who want to travel on S. 70th St. or west on Old Cheney Rd. would have to travel approximately ½ mile out of their way to access Old Cheney Rd. or S. 70th St.
- 8. Section 26.31.010 of the Land Subdivision Ordinance states, "Whenever a lot, tract, or parcel of land is of such unusual size or shape or is surrounded by such development or unusual condition that the strict application of the requirements contained in these regulations would result in actual difficulties or substantial hardship or injustice, the subdivider may request a modification of such requirements."
- 9. Although there have been grading and drainage issues in the past, this sidewalk can be installed by using culverts under the sidewalk.
- 10. Nationally and locally more emphasis is being placed on encouraging people to walk. To facilitate walking, pedestrians must have a safe place to walk. This includes installing sidewalks and separating pedestrians from automobiles.

Prepared by:

Tom Cajka Planner

DATE: November 10, 2004

APPLICANT: Edenton South Town Home Association

Craig Larabee, President

7130 Culwells Ct. Lincoln, NE 68516 (402) 488-0654

OWNER: same as applicant

CONTACT: same as applicant



2002 aerial

Waiver #04016 S. 70th & Old Cheney Rd.


Zoning:

R-1 to R-8Residential District Agricultural District
Agricultural Residential District AG AGR R-C Residential Convervation District 0-1 Office District 0-2 Suburban Office District O-3 Office Park District R-T Residential Transition District B-1 Local Business District B-2 Planned Neighborhood Business District Commercial District B-3 Lincoln Center Business District B-4 B-5 Planned Regional Business District H-1 Interstate Commercial District H-2 Highway Business District H-3 **Highway Commercial District** H-4 General Commercial District Industrial District I-1

One Square Mile Sec. 15 T9N R7E







Lincoln City - Lancaster County Planning Dept.


I-2

I-3

Industrial Park District

Employment Center District Public Use District

CORRECTED PLAT OF EDENTON**SOUTH** 10TH ADDITION



70TH



CHARLES THONE DONALD H. ERICKSON WM. E. MORROW, JR. SAM JENSEN DANIEL B. KINNAMON THOMAS J. GUILFOYLE VIRGIL K. JOHNSON CHARLES V. SEDERSTROM CHARLES D. HIMBLE ALAN M. WOOD WILLIAM F. AUSTIN JOHN C. BROWNRIGG THOMAS J. CULHANE RICHARD J. GILLOON SAMUEL E CLARK GARY L. HOFFMAN MARK M. SCHORR JERALD L. RAUTERKUS WILLIAM T. FOLEY PATRICK R. GUINAN

LAW OFFICES

ERICKSON & SEDERSTROM, P.C.

A LIMITED LIABILITY ORGANIZATION

SUITE 400 301 SOUTH 13TM STREET LINCOLN, NEBRASKA 68508-2571 TELEPHONE (402) 476-1000 FACSIMILE (402) 476-6167

WRITER'S INTERNET ADDRESS

humble@estaw.com

JULIE A. JORGENSEN
JOHN B. MORROW
MICHELLE B. MILLER
TIERNAN T. SIEMS
JASON R. YUNGTUM
PAUL D. HEIMANN
MATTHEW V. RUSCH
KRISTINE J. GATES
ANGELA PROBASCO
TRENT J. MARTINET
NICOLE M. LUCIUS

OF COUNSEL

DAVID J. NÆLSEN DONALD B. STENBERG

OMAHA OFFICE 10330 REGENCY PARKWAY DRIVE, SUITE 100 OMAHA, NEBRASKA 64114 (402) 397-2200

PURPOSE STATEMENT

Constructing a sidewalk in this pedestrian area will have the effect of creating a "dam" situation causing water to back up and onto the adjacent private properties. In addition to the potential water problems, the chances of pedestrians actually using this pedestrian way is greatly diminished by the fact that it leads into a private roadway, which on one end is a cul-de-sac. Attached is a petition signed by homeowners of Edenton South Townhome Association expressing their opposition to the referenced pedestrian way. Also attached is a Plat of the area showing where the pedestrian way is located.



CHARLES THONE
DONALD H. ERICKSON
WM. E. MORROW, JR.
SAM JENSEN
DANIEL B. KINNAMON
THOMAS J. GUILFOYLE
VIRGIL K. JOHNSON
CHARLES V. SEDERSTROM
CHARLES D. HUMBLE
ALAN M. WOOD
WILLIAM F. AUSTIN
JOHN C. BROWNRIGG
THOMAS J. CULHANE
RICHARD J. GILLOON
SAMUEL E. CLARK
GARY L. HOFFMAN
MARK M. SCHORR
JERALD L. RAUTERKUS
WILLIAM T. FOLEY
PATRICK R. GUINAN

ERICKSON & SEDERSTROM, P.C.

A LIMITED LIABILITY ORGANIZATION

SUITE 400 301 SOUTH 13TM STREET LINCOLN, NEBRASKA 68508-2571 TELEPHONE (402) 476-1000 FACSIMILE (402) 476-6167

WRITER'S INTERNET ADDRESS

humble@eslaw.com

JULIE A. JORGENSEN
JOHN B. MORROW
MICHELLE B. MILLER
TIERNAN T. SIEMS
JASON R. YUNGTUM
PAUL D. HEIMANN
MATTHEW V. RUSCH
KRISTINE J. GATES
ANGELA PROBASCO
TRENT J. MARTINET
NICOLE M. LUCIUS


OF COUNSEL

DAVID J. NIELSEN DONALD B. STENBERG

OMAHA OFFICE 10330 REGENCY PARKWAY DRIVE, SUITE 100 OMAHA, NEBRASKA 68114 (402) 397-2200

LIST OF ALL WAIVERS BEING REQUESTED

A waiver is being requested of Section 26.23.095 of the Land Subdivision Ordinance which requires that concrete sidewalks be constructed in pedestrian ways.



War . Hills	7030 Pal SPLONET
Muey on	7040 Calwells C+
The state of the s	1040 Calmetts CF
Bruce Cline & Alena	7045 Calux115 Ct
me I Coul truse	7014 Calare A
un Barty Alt	Hallmen 2501
Cy Raitzact	7020 Calcalle 1-
A Paggy maketterick	7125 Coloralis CT
E. & Sec. Juniole	TOAL Calmette St.
de + Tilaran More	7650 Culmella C
Entre trene	727 algan C
$f_{ij} = f_{ij} = f_{ij}$	7154 calculle it
	7011 Camero St.
	my how 7027 Calina
lea Torna Javione	7140 Redweller St.
and the - when	1031 Culwelle Ct
a proportion al wood	7,44 Calmette CT
~ + June Gooding	7160 CULWELLS CT
Laster Inst Jacker	7130 Culwells &
nt and Janet Remmenge	7150 Culwelle Ct.
toring Mac Donald	7121 Culwelle Ct
ent : Virginia Olson	•
My Jaraha 1216	103

GENTRAL KOTARY - STATE OF MEMASIA

CRAIG LARABEE

COLUMN EXP. 1-6-05

Memorandum

To:	Tom Cajka, Planning Department	
From:	Charles W. Baker, Public Works and Utilities	
Subject:	Waiver #04016 Pedestrian Easement Edenton South	
Date:	November 10, 2004	
cc:	Randy Hoskins	
	Harry Kroos	

The City Engineer's Office of the Department of Public Works and Utilities has reviewed the request to remove the pedestrian easement on the southeast corner of 70th and Old Cheney to the southeast onto Culwells Court. Public Works has the following comment:

• The waiver request states that construction of the sidewalk in the pedestrian easement will cause a damming effect on the drainage of this area. That condition can be alleviated with culverts in the swale area under the sidewalk within the easement. Public Works has visited this site on several occasions about the drainage problems and standing water in this area. The sidewalk construction in this area should be engineered since the grading plan has been adjusted to compensate for the drainage and to meet ADA requirements.